

Hazardous Area Safety Check List

1) Hazardous Area Training

(See clause 1.7 of AS/NZS2381.1:2005)

All personnel (including operators, managers, supervisors, technicians and engineers):

Have Been Trained

Have Attended Regular Refresher Training (every 2 to 3 years)

2) Classification of Hazardous Areas

(See clause 7.7.2.1 of AS/NZS3000:2007)

All Hazardous Areas have been formally classified

Classification has been reviewed regularly (every 2 to 3 years)

3) Inspections

(See section 4 of AS/NZS2381.1:2005)

Each item of Hazardous Area electrical equipment and wiring complies with relevant Australian Standards

The hazardous area electrical installations have had Regular Inspections (every 1 to 2 years)

4) Verification Dossier

(See clause 1.6 of AS/NZS2381.1:2005)

Verification Dossier for every hazardous area plant

Verification Dossier is up-to date

5) Standards

Have the relevant Hazardous Area Australian Standards

Standards are up-to-date